



GOVERNMENT OF TELANGANA STATE

OFFICE OF THE DISTRICT MEDICAL & HEALTH OFFICER, KARIMNAGAR

Re. No. 1010/DEMO/MEM/HE/2026

Date: - 09 -2026

SC.No. /2026.

**AS PER APPENDIX -14
(RWE- 84 CHAPTER II)**

**SANITARY CERTIFICATE FOR THE PURPOSE OF THE
RECOGNITION**

The District Health Educator has inspected the, CHALMEDA ANANDARAO
UNIVERSAL SCHOOL (A Unit of Arihant Educational Society) Sy.No.122, Bommakal,
KARIMNAGAR - 505001 of Karimnagar Dist and certified that the accommodation provided
for each of the several classes is sufficient for the maximum number of pupil through there in
and is properly ventilated and the building is maintained in substantial repairs that is neat and
hygienic, the latrine arrangements are adequate and satisfactory.

The support of "Sanitation, Ventilation and Safe Drinking Water facilities in the
School/College, are provided and that in all other necessary respects the sanitation is good".

Station: Karimnagar
Date: - 09 -2026

[Signature] 26/9/26
Dist. Medical & Health Officer,
KARIMNAGAR.



[Signature]
**PRINCIPAL
CHALMEDA ANAND RAO
UNIVERSAL SCHOOL
BOMMAKAL,
KARIMNAGAR-505 001.**

N. W. S.
**MANAGER / CORRESPONDENT
CHALMEDA ANAND RAO
UNIVERSAL SCHOOL
BOMMAKAL,
KARIMNAGAR-505 001.**



**GOVERNMENT OF TELANGANA
REGIONAL PUBLIC HEALTH LABORATORY, WARANGAL**

HANUMAKONDA (KUDA Premises) - 506 001.

**Report of Physical, Chemical Analysis of Water &
Chemical Analysis of Water for Construction Purpose***

Sample from : The Panchayat

Collected by : Sgt CHALMEDA ANAND RAO ✓

Collected on : UNIVERSAL SCHOOL

Paid / Free :

Received on : 22/9/2011 - Bommalak, Karimnagar

Receipt No. :

Amount : 230 200

Lab Ref. No. :	<u>231912026</u>	<u>2197</u>	IS10500:2012
Address of Sources :		<u>Dainling (R.O)</u>	Acceptable limit
Substance or Characteristic :		<u>Water from School.</u>	Permissible limits in the absence of alternate source
Colour :		<u>15</u>	5
Odour :		<u>Agreeable</u>	Agreeable
Turbidity NTU :		<u>-</u>	1
*pH at °C :		<u>7.1</u>	6.5 - 8.5
Electrical conductivity (at 25° C Micro Mhos /cm) :		<u>210</u>	No relaxation
* Total Dissolved Solids (mg/Lt.) :		<u>136</u>	500
The following results are in mg/liter			
Phenolphthalein Alkalinity :		<u>NIL</u>	
Total Alkalinity (as CaCO ₃) :		<u>8</u>	200
Total hardness (as CaCO ₃) :		<u>18</u>	600
Calcium hardness (as CaCO ₃) :		<u>8</u>	200
Magnesium hardness (as CaCO ₃) :		<u>10</u>	600
Sulphate (as SO ₄ ²⁻) :		<u>-</u>	200
Nitrite (as NO ₂) :		<u>NIL</u>	400
Nitrate (as NO ₃) :		<u>-</u>	10
*Chloride (as Cl) :		<u>10</u>	No relaxation
Fluoride (as F) :		<u>0.08</u>	250
Iron (as Fe) :		<u>-</u>	1.0
*To neutralize 100 ml of water sample using phenolphthalein indicator with 0.02N Na OH (in ml) :			1.5
*To neutralize 100 ml of water sample using Mixed indicator with 0.02N H ₂ SO ₄ (in ml) :			0.3
			Not more than 5 ml as per is 456 (2000) (Reaffirmed 2005)
			Not more than 25 ml as per is 456 (2000) (Reaffirmed 2005)

The Given water Sample is physico-chemically SATISFACTORY for Drinking purpose.

Sulechandra
Senior Analyst
Regional Public Health Laboratory
Hanumakonda.

**PRINCIPAL
CHALMEDA ANAND RAO
UNIVERSAL SCHOOL
BOMMAKAL,
KARIMNAGAR-505 001.**

N. N. N. N.
**MANAGER / CORRESPONDENT
CHALMEDA ANAND RAO
UNIVERSAL SCHOOL
BOMMAKAL,
KARIMNAGAR-505 001.**
Civil Surgeon
Regional Public Health Laboratory,
Hanumakonda.